

For Non-Health Hazard Applications

Job Name _____

Contractor _____

Job Location _____

Approval _____

Engineer _____

Contractor's P.O. No. _____


Approval _____

Representative _____


Piping / Recirculation Diagram

PowerStation™ & Tempering Recirculation Loop

Continuous Aquastat / Recirculation*



***USE AQUASTAT CONTROL ONLY WHEN REQUIRED MINIMUM FLOW IS GREATER THAN OR EQUAL TO THE VALVE MINIMUM FLOW (REFER TO LITERATURE).**



Powers product specifications in U.S. customary units and metric are approximate and are provided for reference only. For precise measurements, please contact Powers Technical Service. Powers reserves the right to change or modify product design, construction, specifications, or materials without prior notice and without incurring any obligation to make such changes and modifications on Powers products previously or subsequently sold.

USA: Tel: (800) 669-5430 • Fax: (847) 229-0526 • PowersControls.com

Canada: Tel: (905) 332-4090 • Fax: (905) 332-7068 • PowersControls.ca

Latin America: Tel: (52) 81-1001-8600 • PowersControls.com

POWERS™

A WATTS Brand